

Backing Rings (AS 4087 B7 PN16 Table D, Table E, ANSI, BS EN 1092 PN16)

BPIR Declaration

Designated building product: Class 1

Declaration

UPG Pipe Systems has provided this declaration to satisfy the provisions of Schedule 1(d) of the Building (Building Product Information Requirements) Regulations 2022.

Product/system

Name	Backing Rings (AS 4087 B7 PN16 Table D, Table E, ANSI, BS EN 1092 PN16)
Line	
Identifier	Codes containing the below identifiers, codes additionally include size and finish identifying elements. AS 4087 B7 PN 16 Table D: <i>5541, 5442, 5444, 5471, 5472</i> Table E: <i>5451, 5452, 5454, 5481, 5482</i> ANSI: <i>5461, 5462, 5465, 5491, 5492</i> BS EN 1092 PN16: <i>5415</i>

Description

Galvanised, Stainless, and Nylon Coated Backing Rings are suited to the Stream PE100 Pressure, Stream HDPE Drainage, Maxair, and Dynatherm PP-RCT ranges.

Scope of use

Backing rings suited to the Stream PE100 Pressure, Stream HDPE Drainage, Maxair, and Dynatherm PP-RCT ranges.

Conditions of use

Design & Installation: Backing Rings as part of Stream PE 100 Pressure Pipes should be installed in accordance with the following Standards:

- General Installation: AS/NZS 2033, "Installation of Polyethylene pipe systems"
- Buried Structural Design: AS/NZS 2566 Part 1 and supplement 1. "Buried Flexible Pipelines - Structural Design"
- Detailed Installation and Site Pressure Testing: AS/NZS 2566 Part 2 "Installation"

Relevant building code clauses

B2 Durability – B2.3.1 (a)

F2 Hazardous building materials – F2.3.1

G10 Piped services – G10.3.1

G12 Water Supplies – G12.3.2, G12.3.7

Supporting documentation

For further information supporting Backing Rings (AS 4087 B7 PN16 Table D, Table E, ANSI, BS EN 1092 PN16) claims refer to our website.

Contact details

Manufacture location	Overseas
Legal and trading name of manufacturer	Fusion Plast Australia Pty Ltd
Legal and trading name of importer	UPG Pipe Systems
Importer address for service	17 Raiha Street Porirua 5022
Importer website	upg.nz
Importer NZBN	9429030885011
Importer email	sales@upg.net.nz
Importer phone number	04 2384452

Responsible person

As the responsible person as set out in Regulation 3, I confirm that the information supplied in this declaration is based on information supplied to the company as well as the company's own processes and is therefore to the best of my knowledge, correct.

I can also confirm that Backing Rings (AS 4087 B7 PN16 Table D, Table E, ANSI, BS EN 1092 PN16) is not subject to a warning on ban under [s26 of the Building Act](#).

Signed for and on behalf of **UPG Pipe Systems**:

James Bolland

James Bolland
Purchasing Manager
December 2023

UPG PIPE SYSTEMS
17 Raiha Street Porirua 5022 New Zealand
[042384452](tel:042384452) | upg.nz

Appendix

Building code performance clauses

B2 Durability

B2.3.1

Building elements must, with only normal maintenance, continue to satisfy the performance requirements of this code for the lesser of the *specified intended life* of the *building*, if stated, or:

- (a) the life of the building, being not less than 50 years, if: those building elements (including floors, walls, and fixings) provide structural stability to the building, or those building elements are difficult to access or replace, or failure of those building elements to comply with the building code would go undetected during both normal use and maintenance of the building

F2 Hazardous building materials

F2.3.1

The quantities of gas, liquid, radiation or solid particles emitted by materials used in the *construction* of *buildings*, shall not give rise to harmful concentrations at the surface of the material where the material is exposed, or in the atmosphere of any space.

G10 Piped services

G10.3.1

Piping systems shall be constructed to avoid the likelihood of:

- a. significant leakage or damage during normal or reasonably foreseeable abnormal conditions,
- b. detrimental contamination of the contents by other substances,
- c. adverse interaction between services, or between piping and electrical systems, and
- d. people having contact with pipes which could cause them harm.

G12 Water Supplies

G12.3.2

A potable *water supply system* must be—

- a. protected from contamination; and
- b. installed in a manner that avoids the likelihood of contamination within the system and the water main; and
- c. installed using components that will not contaminate the water.

G12.3.7

Water supply systems must be installed in a manner that

- a. pipes water to *sanitary fixtures* and *sanitary appliances* at flow rates that are *adequate* for the correct functioning of those *fixtures* and *appliances* under normal conditions; and
- b. avoids the likelihood of leakage; and
- c. allows reasonable access to components likely to need maintenance; and
- d. allows the system and any backflow prevention devices to be isolated for testing and maintenance.